



Exhibit 2 Proposed Well Location and Willmar Ave Water Main Casing



Current well or future well, with a 200-foot MDH isolation distance

Will need to be abandoned due to storm pond.

Minimum 200-foot isolation distance required to site a well.

Water Main Casing